

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7151-1039:104 Page 1 of 1

CATEGORY: Boxes/Pull Stations for Hazradous Locations

LISTEE: RSG Inc., 3300 E. 59th Street, Long Beach, CA 90805
Contact: Louis J. Finkle (310) 630-4684

DESIGN: Models RMS-EX-WP-1T, -2T, -3T, and -6T with or without suffixes DAH, LP or KL non-coded, explosion proof, weather proof manual pull stations. These devices consist of a switch and terminal block mounted within an explosion proof enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 120 VAC, 10 A

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed compatible control units. Suitable for use outdoor and in Class I, Group B, C and D; Class II, Group E, F and G hazardous locations.

NOTE: Formerly 7150-1039:104

*Corrected 10-16-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager